



Danny Brevard <danny@accent-us.com>

Dri-sump(R) Containment Tightness Test Method

Raia, Anthony <Raia.Anthony@epa.gov>

Tue, Mar 17, 2020 at 10:33 AM

To: Danny Brevard <danny@accent-us.com>

Cc: Joseph Pezdan <jpezdan@globalfuelingsystems.com>, "office@accent-us.com" <office@accent-us.com>, "Brauksieck, James (Russ)" <brauksieck.james@epa.gov>

Danny, we just recently posted revised/new Q&A's into our web-based technical compendium about the federal UST regulation...

- Click on <https://www.epa.gov/ust/underground-storage-tank-ust-technical-compendium-about-2015-ust-regulation>
- Then click on "Spill buckets, under dispenser containment sumps, containment sumps"
- Then scroll down to "Containment Sump – Test Procedures"

Per the section entitled *Additional Alternative Test Procedures*, Dri-sump does indeed meet the requirements.

Any questions and/or want to discuss further let me know.

Thanks.

Tony Raia

Anthony Raia

Office of Underground Storage Tanks (OUST)

U.S. Environmental Protection Agency

Office Number: (202) 566-1021

Cell Number: (202) 567-1647

[Quoted text hidden]